**Hygiene-Institut des Ruhrgebiets**
Institut für Umwelthygiene und Toxikologie
Direktor: Prof. Dr. rer. nat. L. Dunemann
**Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.**

Hygiene-Institut · Postfach 10 12 55 · 45812 Gelsenkirchen

Rich. Klinger Dichtungstechnik
GmbH & Co. KG
Am Kanal 8-10
2352 GUMPOLDSKIRCHEN
AUSTRIA

Visitors/ postal address:
Rotthauser Str. 21, 45879 Gelsenkirchen, Germany

| | |
|---|---|
| Switchboard | (0049209) 9242-0 |
| Phone | (0049209) 9242-230 |
| Fax | (0049209) 9242-222 |
| E-Mail | c.schell@hyg.de |
| Internet | www.hyg.de |

Reference: W-285567e-17-Sl/Krü
**Before:** **W-217739-12-Sl**
Contact person: Mrs. Dr. Ch. Schell

Gelsenkirchen, 09.06.2017

# TEST CERTIFICATE

**(Prolongation of test certificate W-217739-12-Sl)**

**Enhancement of Microbial Growth on Materials to Come into Contact with Drinking water**
**Test pursuant to DVGW Technical Standard W 270, November 2007**

| | |
|---|---|
| **Client:** | Rich. Klinger Dichtungstechnik<br>GmbH & Co. KG<br>Am Kanal 8-10<br>2352 GUMPOLDSKIRCHEN<br>AUSTRIA |
| **Test material:** | **KLINGERSIL® C-4430 plus** |
| **Test method:** | Material test |

According to test report **W-217739-12-Sl** of **15.06.2012**, the material **KLINGERSIL® C-4430 plus** is conform to the requirements for the use in the area of drinking water systems pursuant to DVGW Technical Standard W 270 for sealings, joints and gaskets with larger surface etc. (D1) and sealings, joints and gaskets with smaller surface etc. (D2). Details regarding testing procedure and test results are itemized in the test report.
This test certificate is valid from the date of issue and, given that the conditions and requirements remain unaltered, expires on **31.12.2021**.

The Director of the Institute
p.p.

Dr. Ch. Schell
Head of Laboratory
Department of Water Hygiene and Environmental Microbiology

The test results and assessments refer exclusively to the examined test specimens and all applicable statutory regulations. The validity of the document expires in case of modifications in the composition of the material or the processing conditions. This present document may only be published and reproduced unabridged and unaltered. This document is no DVGW certification.