Approval Number: 1408541
Test Report: MA5027/K

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

30th October 2014

Rich. Klinger Dichtungstechnik GmbH & Co KG
Am Kanal 8-10,
A - 2352 Gumpoldskirchen,
Austria

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE **5075**

KLINGERSIL C-4430. NBR/fibre gasket material, which is green coloured one side and white coloured the other, manufactured by calandering. For use with water up to 23°C. For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

APPROVAL NUMBER: 1408541
APPROVAL HOLDER: RICH. KLINGER DICHTUNGSTECHNIK GMBH & CO KG

The Scheme reserves the right to review approval.
Approval 1408541 is valid between August 2014 and August 2019

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme